



Landlord/Home Owner Gas Safety Record

Serial Number


40

Registered Business		Job Address		Landlord/Agent	
Gas Safe ID	213491	Name	Mr Occupier	Name	Any Estates
Company	N Marshall and Son	Address	22 Any Street	Address	1 New Street
Address	18 Melksham Close		Manchester		Macclesfield
	Macclesfield				Cheshire
	Cheshire	Postcode	M12 0HA	Postcode	SK11 0PW
Postcode	SK11 8NH	Telephone		Telephone	
Telephone	01625 269351				

Location					Inspection Details									
Location	Appliance Type	Make	Model	Flue Type	Landlords Appliance	Appliance Inspected	Combustion analyser reading	Operating pressure in mbars heat input	Safety device(s) correct operation	Ventilation provision satisfactory	Visual conditions of flue and termination satisfactory	Flue performance checks	Appliance serviced	Appliance safe to use
Kitchen	Boiler	Glow Worm	Fuelsaver	RS	yes	yes	n/a	13.2	yes	yes	yes	pass	no	yes
Lounge	Fire	Focal Point	Multiflue	OF	yes	yes	n/a	17.2	yes	yes	yes	pass	no	yes
Kitchen	Hob	Whirlpool	600 ga	FL	yes	yes	n/a	20.4	yes	yes	n/a	n/a	no	yes

Gas Installation pipework satisfactory visual inspection	yes	Satisfactory gas tightness test	yes	Defect(s) Identified	Remedial Action Taken	Warning/Advice Notice issued
Emergency Control accessible	yes	Equipotential bonding satisfactory	yes			

Date	29 07 2009	Number of Appliances tested:	3
Gas Operative print name	Steve Marshall	Received by the	homeowner landlord tenant agent
Gas Safe Card ID	2261823	Print name	Mr Man

Engineer Signature  Received by Signed